

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011572.18-R11
DATE: 07/01/2013
CERTIFICATION PROGRAM: Structural
COMPANY: ProVia Door
CODE: 1212-1
REVISION DATE: 07/29/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ProVia LLC 2150 State Route 39 Sugarcreek, OH 44681	Steel In-Swing Glazed Side Hinged Door w/Sidelites Configuration: OXO Glazing: Insulating Glass (Tempered) Frame: W-2598mm(102.32") H-2478mm(97.59") Panel: W-908mm(35.75") H-2411mm(94.94")

SPECIFICATION	PRODUCT RATING
ASTM E330-02	Design Pressure: +45/-50 psf

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-15660-1/NCTL-110-13337-1/NCTL-110-15650-4/
NCTL-110-15651-4/W-1598/W-1978/W-2002/W-2024/W-2103/W-2104
/W-2105/W-2170/W-2199
Expiration Date: **December 31, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION & MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC 03/30/2023