

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI008048.03-R3
DATE: 05/21/2007
CERTIFICATION PROGRAM: Structural
COMPANY: Shwinco
CODE: 1972-1
REVISION DATE: 04/18/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Shwinco Architectural Products, LLC 171 Jet Services Way Dothan, AL 36303	Series "9700" Vinyl Sliding Glass Door Configuration: OXXO Glazing: IG-Exterior-1/4" Tempered Glass/ Interior Laminate-3/16" Heat Strengthened Glass/0.075" PVB by Solutia Interlayer/ 3/16" Heat Strengthened Glass or IG-Exterior-3/16 Tempered Glass/ 3/16 Tempered Glass/0.075" Eastman Chemical Vanceva Interlayer/3/16 Tempered Glass Frame: W-3595mm(141.5") H-2438mm(96") Panel: W-942mm(37.12") H-2369mm(93.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-05 AAMA/NWDA 101/I.S.2-97 ASTM E1886-02/05/13a/E1996-02/05/14a	Class CW-PG65 3595 x 2438 (142 x 96)-SD SD-C65 3595 x 2438 (142 x 96) Design Pressure: ±3112 Pa (65 psf) Wind Zone 4-Missile Level D Water Penetration Resistance Test Pressure w/3.75 Sill Riser: 648 Pa (13.5 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3281-5/NCTL-210-3281-2/W-1930/W-1997
Expiration Date: October 31, 2026

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023