

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI008048.05-R2
DATE: 05/12/2011
CERTIFICATION PROGRAM: Structural
COMPANY: Shwinco
CODE: 1972-1
REVISION DATE: 01/26/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Shwinco Architectural Products, LLC 171 Jet Services Way Dothan, AL 36303	Series "9700" Vinyl Sliding Glass Door Configuration: OXX Glazing: Insulating Glass (Tempered) Frame: W-3734mm(147") H-2438mm(96") Panel: W-1254mm(49.37") H-2369mm(93.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class CW-PG70 3734 x 2438 (147 x 96)-SD SD-C70 3734 x 2438 (147 x 96) Water Penetration Resistance Test Pressure: w/3.75 Sill Riser: 648 Pa (13.5 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3532-3/NCTL-210-3281-2/W-1930
Expiration Date: **October 31, 2026**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023