

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011489-R9
DATE: 03/06/2013
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 07/21/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Contours Steel (S-2500) Wood Edge" Steel Glazed Side Hinged Door Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-953mm(37.50") H-2052mm(80.75") Panel: W-909mm(35.75") H-2013mm(79.25") DLO: W-499mm(19.63") H-397mm(15.63")

SPECIFICATION	PRODUCT RATING
TAS 202-94	Design Pressure: 2634 Pa (55 psf) Negative Design Pressure: 2634 Pa (55 psf) Water Penetration Resistance Test Pressure: 396 Pa (8.25 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3857-1/A009078/W-1897/W-1905/W-2025/W-2039
Expiration Date: **January 31, 2030**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "MD".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023