

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013877.17
DATE: 08/24/2022
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Aurora Custom" Glazed Full Lite Fiberglass In-Swing Fiberglass Side-Hinged Door Assembly w/Sidelites Configuration: OXXO Glazing: IG-3/16" Tempered Glass/1/8" Annealed Glass/0.090" DuPont SGP Interlayer/1/8" Annealed Glass Frame: W-3480mm(137") H-2480mm(97.63") Panel: W-1060mm(41.75") H-2407mm(94.75") DLO: W-806mm(31.75") H-2191mm(86.25")

SPECIFICATION	PRODUCT RATING
ASTM E1886-12/13a ASTM E1996-09/12a/14a	Design Pressure: ±2400 Pa (50 psf) Wind Zone 3 - Missile Level D

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-310-22-067
Expiration Date: August 31, 2026

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com