

Hallmark® Certificate of Conformance and License (CCL)



AMS, INC.
Administrative Management
Systems, Inc.

Kolbe & Kolbe Millwork Co.
1323 South 11th Avenue
Wausau, WI 54401

Mfr ID: 413

For more Information visit www.amscert.com

Website: www.kolbewindows.com

TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
413-H-1070.123	Ultra Sliding Door, Rect, SP, (R&D 23001 Recert 13104/16112)	101/I.S.2/A440-22	Class LC-PG45; Size Tested 2438mm x 2500mm Type-SD; DP +45/-45 psf; Water Test Press 330Pa (6.89psf)	2438mm	2500mm	QCT23-6906.34	6/25/2024	6/10/2034
413-H-1070.124	Ultra Sliding Door, Rect, SP, (R&D 23001 Recert 13104/16112)	101/I.S.2/A440-17	Class LC-PG45; Size Tested 2438mm x 2500mm Type-SD; DP +45/-45 psf; Water Test Press 330Pa (6.89psf)	2438mm	2500mm	QCT23-6906.34	6/25/2024	6/10/2034
413-H-1070.125	Ultra Sliding Door, Rect, SP, (R&D 23001 Recert 13104/16112)	CSA A440 S1-17	Class LC-PG45; Size Tested 2438mm x 2500mm Type-SD; DP +2160/-2160 Pa (+45/-45 psf); Water Test Press 330Pa (6.89psf)	2438mm	2500mm	QCT23-6906.34	6/25/2024	6/10/2034
413-H-1070.126	Ultra Sliding Door, Rect, SP, (R&D 23001 Recert 13104/16112)	CSA A440 S1-19	Class LC-PG45; Size Tested 2438mm x 2500mm Type-SD; DP +2160/-2160 Pa (+45/-45 psf); Water Test Press 330Pa (6.89psf); Can. Air Infil/Exfil. Level=A3	2438mm	2500mm	QCT23-6906.34	6/25/2024	6/10/2034
413-H-1080.51	Heritage DH Sash Set Transom (HWT1W1858/1609) SP (R&D 23082 New Cert)	101/I.S.2/A440-22	Class CW-PG65; Size Tested 2438mm x 1524mm Type-FW; DP +65/-65 psf; Water Test Press 470Pa (9.82psf)	2438mm	1524mm	QCT24-7203.07	6/25/2024	5/7/2034
413-H-1080.52	Heritage DH Sash Set Transom (HWT1W1858/1609) SP (R&D 23082 New Cert)	101/I.S.2/A440-17	Class CW-PG65; Size Tested 2438mm x 1524mm Type-FW; DP +65/-65 psf; Water Test Press 470Pa (9.82psf)	2438mm	1524mm	QCT24-7203.07	6/25/2024	5/7/2024
413-H-1256.14	Ultra Inswing Door Sidelite Narrow Stiles, EE, SP (R&D 23011 recert 13028)	101/I.S.2/A440-22	Class CW-PG65; Size Tested 1273mm x 2507mm Type-FD; DP +65/-70 psf; Water Test Press 510Pa (10.65psf)	1273mm	2507mm	QCT23-6906.39	6/25/2024	4/29/2034
413-H-1256.15	Ultra Inswing Door Sidelite Narrow Stiles, EE, SP (R&D 23011 recert 13028)	101/I.S.2/A440-17	Class CW-PG65; Size Tested 1273mm x 2507mm Type-FD; DP +65/-70 psf; Water Test Press 510Pa (10.65psf)	1273mm	2507mm	QCT23-6906.39	6/25/2024	4/29/2034
413-H-1256.16	Ultra Inswing Door Sidelite Narrow Stiles, EE, SP (R&D 23011 recert 13028)	CSA A440 S1-17	Class CW-PG65; Size Tested 1273mm x 2507mm Type-FD; DP +3120/-3360 Pa (+65/-70psf); Water Test Press 510Pa (10.65psf)	1273mm	2507mm	QCT23-6906.39	6/25/2024	4/29/2034

Hallmark® Certificate of Conformance and License (CCL)



Kolbe & Kolbe Millwork Co.
1323 South 11th Avenue
Wausau, WI 54401

Mfr ID: 413

For more Information visit www.amscert.com

Website: www.kolbewindows.com

TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
413-H-1256.17	Ultra Inswing Door Sidelite Narrow Stiles, EE, SP (R&D 23011 recert 13028)	CSA A440 S1-19	Class CW-PG65; Size Tested 1273mm x 2507mm Type-FD; DP +3120/-3360 psf; Water Test Press 510Pa (10.65psf); Can. Air Infil/Exfil. Level=Fixed	1273mm	2507mm	QCT23-6906.39	6/25/2024	4/29/2034
413-H-1256.18	Ultra Inswing Door Sidelite Narrow Stiles, IPD4 (R&D 23012/23013 recert 13030/13029)	101/I.S.2/A440-22	Class CW-PG65; Size Tested 1273mm x 2507mm Type-FD; DP +65/-70 psf; Water Test Press 470Pa (9.82psf)	1273mm	2507mm	QCT23-6906.16	6/25/2024	1/5/2034
413-H-1256.19	Ultra Inswing Door Sidelite Narrow Stiles, IPD4 (R&D 23012/23013 recert 13030/13029)	101/I.S.2/A440-17	Class CW-PG65; Size Tested 1273mm x 2507mm Type-FD; DP +65/-70 psf; Water Test Press 470Pa (9.82psf)	1273mm	2507mm	QCT23-6906.16	6/25/2024	1/5/2034
413-H-1256.20	Ultra Inswing Door Sidelite Narrow Stiles, IPD4 (R&D 23012/23013 recert 13030/13029)	CSA A440 S1-17	Class CW-PG65; Size Tested 1273mm x 2507mm Type-FD; DP +3120/-3360 Pa (+65/-70 psf); Water Test Press 470Pa (9.82psf)	1273mm	2507mm	QCT23-6906.16	6/25/2024	1/5/2034
413-H-1256.21	Ultra Inswing Door Sidelite Narrow Stiles, IPD4 (R&D 23012/23013 recert 13030/13029)	CSA A440 S1-19	Class CW-PG65; Size Tested 1273mm x 2507mm Type-FD; DP +3120/-3360 Pa (+65/-70 psf), Wind Zone 4; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=Fixed	1273mm	2507mm	QCT23-6906.16	6/25/2024	1/5/2034
413-H-1267.30	VistaLuxe Awning, Rect SP (R&D #22097 New Cert)	101/I.S.2/A440-22	Class LC-PG50; Size Tested 914mm x 1219mm Type-AP; DP +50/-50 psf; Water Test Press 360Pa (7.52psf)	914mm	1219mm	QCT24-7203.19	6/25/2024	5/28/2034
413-H-1267.31	VistaLuxe Awning, Rect SP (R&D #22097 New Cert)	101/I.S.2/A440-17	Class LC-PG50; Size Tested 914mm x 1219mm Type-AP; DP +50/-50 psf; Water Test Press 360Pa (7.52psf)	914mm	1219mm	QCT24-7203.19	6/25/2024	5/28/2034
413-H-1267.32	VistaLuxe Awning, Rect SP (R&D #22097 New Cert)	CSA A440 S1-17	Class LC-PG50; Size Tested 914mm x 1219mm Type-AP; DP +2400/-2400 Pa (+50/-50 psf); Water Test Press 360Pa (7.52psf)	914mm	1219mm	QCT24-7203.19	6/25/2024	5/28/2034



Hallmark® Certificate of Conformance and License (CCL)



AMS, INC.
Administrative Management
Systems, Inc.

Kolbe & Kolbe Millwork Co.
1323 South 11th Avenue
Wausau, WI 54401

Mfr ID: 413
For more Information visit www.amscert.com
Website: www.kolbewindows.com
TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
413-H-1267.33	VistaLuxe Awning, Rect SP (R&D #22097 New Cert)	CSA A440 S1-19	Class LC-PG50; Size Tested 914mm x 1219mm Type-AP; DP +2400/-2400 Pa (+50/-50psf); Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	914mm	1219mm	QCT24-7203.19	6/25/2024	5/28/2034

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By: John McFee John McFee, VP of Certification Programs, WDMA Hallmark

By: Lucas L. Wenzel Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com

