

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010216.01-R3
DATE: 04/29/2010
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 11/30/2017

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	"Contractor Series 2000/HarborLight/ Home Craftsman 8125/Mastic 3000" Prime Window-Repair & Replacement Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-2540mm(100) H-1448mm(57") DLO: W-2394mm (94.25") H-1303mm (51.31")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-05	FW-LC55 2540 x 1448 (100 x 57) Design Pressure: 2633 Pa (55 psf) Negative Design Pressure: 2633 Pa (55 psf) Water Penetration Resistance Test Pressure: 575 Pa(12 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-12898-2
Expiration Date: March 31, 2028

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi" or similar, written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122