

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010219.03-R2
DATE: 04/30/2010
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 01/16/2018

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	"Contractor Series 2000" Tilt Double Hung Vinyl Prime Window Configuration: X/X Glazing: Insulating Glass (Annealed) Frame: W-1370mm(53.94) H-2029mm(79.88") Sash: W-1295mm (51") H-1003mm (39.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-05	H-R20 1370 x 2029 (54 x 80) Design Pressure: 958 Pa (20 psf) Negative Design Pressure: 958 Pa (20 psf) Water Penetration Resistance Test Pressure: 251 Pa (5.25 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-12899-4/NCTL-110-12899-3
Expiration Date: **April 30, 2028**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122