



LISTING INFORMATION OF

LIF Steel Stiffened Hollow Metal Windstorm Door and Frame Assemblies

SPEC ID: 22885

LIF Industries
5 Harbor Park Drive
Port Washington, NY 11050
United States

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

LISTING INFORMATION

PRODUCT DESCRIPTION

LIF Steel Stiffened Hollow Metal Windstorm Door and Frame Assemblies are windstorm resistant door and frame outswing assemblies that are configured as single swing (SC1, SC2, SC3) and pair assemblies (PC1, PC2, PC4, PC5).

WINDSTORM RATINGS

LIF Steel Stiffened Hollow Metal Windstorm Door and Frame Assemblies *		Maximum Nominal Size	Latching Hardware	Standards / Rating
Single Outswing	SC1	3'-0" × 7'-0" × 1-3/4"	Corbin Russwin CL3300 Series Cylindrical Lock	ASTM E330-14 ASTM E1886-13a ASTM E1886-19 ASTM E1996-17 ASTM E1996-20 Design Pressure: + 70 PSF / -70 PSF Impact: 350 ft-lbs
	SC2	3'-0" × 7'-0" × 1-3/4"	Sargent 8200 Series Mortise Lock	
	SC3	3'-0" × 7'-0" × 1-3/4"	Yale 7150 FWS with Windstorm Interlocking bracket	
Pairs Outswing	PC1	6'-0" × 7'-0" × 1-3/4"	Active: Corbin Russwin CL3300 Series Cylindrical Lockset Inactive: Yale 988Y Surface Bolts	
	PC2	6'-0" × 7'-0" × 1-3/4"	Active: Sargent 8200 Series Mortise Inactive: Sargent 988 Surface Bolts	
	PC4	6'-0" × 7'-0" × 1-3/4"	Yale 7150 Exit device with Windstorm interlocking bracket on both leaves Removable Mullion: Yale M200FWS	
	PC5	6'-0" × 7'-0" × 1-3/4"	Concealed Vertical Rod Exit Device Sargent 8600 or, Surface Mounted Vertical Rod Sargent HC8700	

* Notes:

The door slabs of all assemblies have been found to be stiffness classification "I" following the procedures in ANSI A250.13 (2003) Section 8.2.

All door assemblies include three McKinney TA 2714 Butt hinges per door leaf.

FLORIDA PRODUCT APPROVAL

Product	Florida Product Approval No.
---------	------------------------------

LIF Steel Stiffened Hollow Metal
Windstorm Door and Frame Assemblies

FL # 13966

Attribute	Value
Criteria	ANSI A250.13 (2003)
Criteria	ASTM E330 (2014) (R2021)
Criteria	ASTM E1996 (2017)
Criteria	ASTM E1996 (2020)
Criteria	ASTM E1886 (2019)
Criteria	ASTM E1886 (2013a)
CSI Code	08 11 13 Hollow Metal Doors and Frames
DP Rating (psf)	70
Hurricane Impact Load Rating ft-lb	350
Listing Section	WINDSTORM - SWING DOOR ASSEMBLIES
Spec ID	22885