

Hallmark® Certificate of Conformance and License (CCL)



AMS, INC.
Administrative Management
Systems, Inc.

Marvin Windows and Doors
PO Box 100
401 State Ave N.
401 State Ave N.
Warroad, MN 56763

Mfr ID: 407


For more Information visit www.amscert.com

Website: www.marvin.com

TEL: 218-386-1430

<i>Product No.</i>	<i>Product Name</i>	<i>Standard</i>	<i>Rating</i>	<i>Wide</i>	<i>High</i>	<i>Test Report #</i>	<i>CertDate</i>	<i>ExpDate</i>
407-H-898.92	Elevate Casement 2W2H ELCAP	101/I.S.2/A440-11	Class LC-PG50; Size Tested 2134mm x 2394mm Type-FW; DP +50/-50 psf; Water Test Press 360Pa (7.52psf)	2134mm	2394mm	H0533.01-201-47	8/28/2017	5/1/2027
407-H-898.93	Elevate Casement 2W2H ELCAP	AAMA 450-10	Class LC-PG50; Size Tested 2134mm x 2394mm Type-FW; DP +50/-50 psf; Water Test Press 360Pa (7.52psf)	2134mm	2394mm	H0533.01-201-47	8/16/2017	5/1/2027

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  *John McFee, VP of Certification Programs, WDMA Hallmark*

By:  *Lucas L. Wenzel, Authorized Representative, AMS*

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com