

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006742.01-R12
DATE: 09/22/2006
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 09/05/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series "4720-F" Aluminum Horizontal Sliding Prime Window Configuration: XO Glazing: Insulating Glass (Annealed) Frame: W-1829mm(72") H-1219mm(48") Panel: W-862mm(33.93") H-1130mm(44.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/NWWDA 101/I.S.2-97	Class R-PG50 1829 x 1219 (72 x 48)-HS HS-R50 1829 x 1219 (72 x 48) Design Pressure: ± 2400 Pa (± 50 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 3208 Pa (67 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-10177-1/NCTL-110-10125-1/W-1958/W-2047
Expiration Date: March 31, 2029

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S. D." or similar, written over a horizontal line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30-2023