

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006468-R8
DATE: 03/31/2006
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 03/31/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series "701/701N/701F/705" Aluminum Fixed Window Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-1219mm(48") H-2134mm(84") DLO: W-1118mm(44") H-2057mm(81")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 AAMA/NWWDA 101/I.S.2-97 ASTM F588-04	Class R-PG40 1219 x 2134 (48 x 84)-FW F-R40 1219 x 2134 (48 x 84) Design Pressure: 1915 Pa (40 psf) Water Penetration Resistance Pressure: 290 Pa (6.00 psf) FER-Passed

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-9966/W-2010
Expiration Date: October 31, 2030

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "MD" or similar, written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023