

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI008098-R7
DATE: 06/05/2007
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 05/14/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namincertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series "4701FL" Aluminum Fixed Window Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1346mm(53") H-1829mm(72")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 AAMA/NWDA 101/I.S.2-97 ASTM F588-04	Class R-PG50 1346 x 1829 (53 x 72)-FW F-R50 1346 x 1829 (53 x 72) Design Pressure: 2394 Pa (50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.50 psf) FER-Passed

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-10389-1/W-2010
Expiration Date: October 31, 2030

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "MD" or similar, written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023