

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010007-R5  
DATE: 09/02/2009  
CERTIFICATION PROGRAM: Structural  
COMPANY: Ply Gem  
CODE: 1411-1  
REVISION DATE: 03/13/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS                                                                    | PRODUCT DESCRIPTION                                                                                                                                                                                                |
|---------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Ply Gem Window Group</b><br><b>433 North Main Street</b><br><b>Rocky Mount, VA 24151</b> | <b>"Builder Series 4701FL"</b><br><b>Fixed Aluminum Window</b><br><br>Configuration: O<br>Glazing: Insulating Glass (Tempered)<br><br>Frame: W-1829mm(72") H-2438mm(96")<br>DLO: W-1734mm(68.25") H-2345mm(92.31") |

| SPECIFICATION                                                                                                                            | PRODUCT RATING                                                                                                                                                                                                                                         |
|------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| AAMA/WDMA/CSA 101/I.S.2/A440-17<br>AAMA/WDMA/CSA 101/I.S.2/A440-11<br>AAMA/WDMA/CSA 101/I.S.2/A440-08<br>AAMA/WDMA/CSA 101/I.S.2/A440-05 | <b>Class LC-PG40 1829 x 2438 (72 x 96)-FW</b><br><b>FW-LC40 1829 x 2438 (72 x 96)</b><br><b>Design Pressure: 1920 Pa (40 psf)</b><br><b>Negative Design Pressure: 1920 Pa (40 psf)</b><br>Water Penetration Resistance Test Pressure: 359 Pa(7.50 psf) |

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-12325-1/W-1988  
Expiration Date: July 31, 2027

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023