NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI012867.01-R3**
DATE:	**09/28/2015**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Pioneer**
CODE:	**1572-1**
REVISION DATE:	**10/26/2021**

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
AADG Inc. dba Pioneer Industries **111 Kero Road** **Carlstadt, NJ 07072**	**Series "Piocane"** **Outswing Steel Glazed Exterior Storefront** **Entrance Side-Hinged Double Doors** Configuration: OOOO/OXXO Glazing: Monolithic- 3/16" Annealed Glass/0.090" Glasslam Safety Plus II/3/16" Annealed Glass Frame: W-3861mm(152") H-3175mm(125") Panel: W-1213mm(47.75") H-2426mm(95.5") DLO: W-575mm(22.63") H-1997mm(78.63")

SPECIFICATION	PRODUCT RATING
TAS 202-94 **AAMA 501-05**	**Design Pressure: +50/-50 psf**

Product Tested By: Fenestration Testing Laboratory, Inc.
Report No: 10-660/W-1754
Expiration Date: **September 30, 2023**

Administrator's Signature: _____

NATIONAL ACCREDITATION & MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122