

NOTICE OF PRODUCT CERTIFICATION



Company: JELD-WEN Exterior Doors
3737 Lakesport Drive
Klamath Falls, OR 97601

Certification No.: NI012741-R6
Certification Date: 04/17/2012
Expiration Date: 04/30/2030
Revision Date: 07/21/2026

Product: "Contours Steel (S-2500) Wood Edge" Impact Rated Opaque Steel Door w/ or w/o Impact & Non-Impact Rated Glazed Sidelites (w/ wood frame unless specified)

Specification: TAS 201/202/203-94

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Design Pressure Pos/Neg	Missile Impact Rated	Test Report Number Drawing Number & Comments
X Single	I/S	Opaque	3'2" x 6'10"	+65/65 psf	Yes	NCTL-210-3801-2/FL 1802/W-1905/W-2025/W-2039 Max Panel Size: 3'0" x 6'8" Installation Details: JW-32012FL
X Single	O/S	Opaque	3'2" x 6'9"	+65/65 psf	Yes	NCTL-210-3801-2/FL 1802/W-1905/W-2025/W-2039 Max Panel Size: 3'0" x 6'8" Installation Details: JW-32012FL
OXO Single w/Sidelites	I/S	Door-Opaque Sidelite-Glazed	9'5" x 6'10"	+65/65 psf	Door-Yes Sidelite-No	NCTL-210-3801-2/FL 1802/W-1905/W-2025/W-2039 Max Panel Size: 3'0" x 6'8"/Daylight Opening: 1'9" x 5'3" Glazing: IG- 1/8" Tempered Installation Details: JW-32012FL
OXO Single w/Sidelites	O/S	Door-Opaque Sidelite-Glazed	9'5" x 6'9"	+65/65 psf	Door-Yes Sidelite-No	NCTL-210-3801-2/FL 1802/W-1905/W-2025/W-2039 Max Panel Size: 3'0" x 6'8"/Daylight Opening: 1'9" x 5'3" Glazing: IG- 1/8" Tempered Installation Details: JW-32012FL
OXO Single w/Sidelites	I/S	Door-Opaque Sidelite-Glazed	9'5" x 6'10"	+65/65 psf	Door-Yes Sidelite-Yes	NCTL-210-3801-2/FL 1802/W-1905/W-2025/W-2039 Max Panel Size: 3'0" x 6'8"/Daylight Opening: 1'9" x 5'3" Glazing: IG- Laminate-1/8" Annealed Glass/.090" Solutia PVB Interlayer/1/8" Annealed Glass/1/8" Tempered Glass Installation Details: JW-32012FL
OXO Single w/Sidelites	O/S	Door-Opaque Sidelite-Glazed	9'5" x 6'9"	+65/65 psf	Door-Yes Sidelite-Yes	NCTL-210-3801-2/FL 1802/W-1905/W-2025/W-2039 Max Panel Size: 3'0" x 6'8"/Daylight Opening: 1'9" x 5'3" Glazing: IG- Laminate-1/8" Annealed Glass/.090" Solutia PVB Interlayer/1/8" Annealed Glass/1/8" Tempered Glass Installation Details: JW-32012FL

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072
Tel: (804) 684-5124/nami@namiinc.com

NAMI AUTHORIZED SIGNATURE: _____