

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009020.03-R5
DATE: 04/26/2011
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1
REVISION DATE: 03/17/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 16341 Domestic Avenue Ft. Myers, FL 33912	Series "FWI 1000" Aluminum Impact Rated Single Hung Window Configuration: O/X Glazing: IG-1/8" Heat Strengthened Glass 0.090" Safelex by Solutia/1/8" Heat Strengthened Glass/0.250" Air Space/1/8" Heat Strengthened Glass Frame: W-1219mm(48") H-1829mm(72") Sash: W-1194mm(47") H-965mm(38")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: +75/-75 psf Large Missile Impact Rated

Product Tested By: National Certified Testing Labs/Fenestration Testing Laboratory, Inc.
Report No: NCTL-210-3374-1/FTL-3598-File No. 02-311/W-2184
Expiration Date: December 31, 2027

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com

NOPC-03/30/2023