

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006177.01-R4
DATE: 04/13/2011
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1
REVISION DATE: 06/04/2015

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 10030 Bavaria Road Ft. Myers, FL 33913	Series "1000" Aluminum Single Hung Window Configuration: O/X Glazing: Monolithic (Annealed) Frame: W-1350mm(53.13") H-1956mm(77") Sash: W-1273mm(50.13") H-962mm(37.88")

SPECIFICATION	PRODUCT RATING
ANSI/AAMA/NWDA 101/I.S.2-97 AAMA 1302.5-76	H-LC45 1350 x 1956 (53 x 77) FER-Passed

Product Tested By: Fenestration Testing Laboratory, Inc.
Report No: Lab No. 3421 & 3422/File No. 02-311
Expiration Date: **June 30, 2020**

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122