

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010607-R2
DATE: 05/09/2011
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1
REVISION DATE: 08/05/2014

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 10030 Bavaria Road Ft. Myers, FL 33913	Series "1431" Vinyl Single Hung Window w/Nailing Fin Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1207mm(47.5") H-1816mm(71.5") Sash: W-1127mm(44.38") H-889mm(35")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-05	H-R50 1207 x 1816 (48 x 72)

Product Tested By: Architectural Testing, Inc.
Report No: 66892.07-109-47/66896.07-109-47
Expiration Date: **December 31, 2019**

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122