

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012533-R2
DATE: 02/25/2015
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1
REVISION DATE: 11/14/2016

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>Eastern Architectural Systems</p> <p>10030 Bavaria Road</p> <p>Ft. Myers, FL 33913</p>	<p style="text-align: center;">Series "2451"</p> <p style="text-align: center;">Vinyl Fin Frame Impact</p> <p style="text-align: center;">Single Hung Window</p> <p style="text-align: center;">Configuration: O/X</p> <p style="text-align: center;">Glazing: Operable IG-Ext-1/8" Annealed Glass/Laminate-1/8" Annealed Glass/0.090" Solutia PVB Interlayer/1/8" Annealed Glass & Fixed IG-Ext-Laminate-1/8" Annealed Glass/0.090" Solutia PVB Interlayer/1/8" Annealed Glass/Int-1/8" Annealed Glass</p> <p>Frame: W-1219mm(48") H-1829mm(72")</p> <p>Sash: W-1143mm(45") H-876mm(34.50")</p> <p>DLO: W-1092mm(43") H-829mm(32.63")</p>

SPECIFICATION	PRODUCT RATING
<p>AAMA 506-08</p> <p>AAMA/WDMA/CSA 101/I.S.2/A440-05</p> <p>ASTM E1886-05/E1996-06</p>	<p>Design Pressure: ±2400 Pa (50 psf)</p> <p>H-R50 1219 x 1829 (48 x 72)</p> <p>Wind Zone 4-Missile Level D</p> <p>Water Penetration Resistance Test Pressure: 360 Pa(7.52 psf)</p>

Product Tested By: Element Materials Technology
 Report No: ESP009376P-2R/010455P-2R
 Expiration Date: **February 28, 2022**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
 Fax: (804) 684-5122