

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013364.02
DATE: 01/17/2017
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 16341 Domestic Avenue Ft. Myers, FL 33912	Series "2451 SH" Vinyl Single Hung Window w/Fin Frame Configuration: O/X Glazing: IG-1/8" Annealed Glass/Laminate-1/8" Annealed Glass/0.090" Eastman Interlayer/1/8" Annealed Glass Frame: W-2919mm(48") H-1829mm(72") Sash: W-1143mm(45") H-876mm(34.5") DLO: W-1092mm(43") H-829mm(32.63")

SPECIFICATION	PRODUCT RATING
AAMA 506-08 ASTM E1886-02/E1996-02 AAMA/WDMA/CSA 101/I.S.2/A440-05	H-R50 1219 x 1829 (48 x 72) Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 359 Pa(7.5 psf) Wind Zone 4 - Missile Level D

Product Tested By: Element Materials Technology
Report No: ESP009376P-10R/010455P-10R/CTLA 2062W-8/W-1797
Expiration Date: September 30, 2018

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122