

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009044.02-R4
DATE: 12/10/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1
REVISION DATE: 04/14/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 10030 Bavaria Road Ft. Myers, FL 33913	Series "90° FD8100-LMI" Impact Rated 90 Degree Aluminum Sliding Glass Door Configuration: XXXXXXXX Four Track Glazing: Laminate-3/16" Heat Strengthened Glass/0.100" Solutia Interlayer/3/16" Heat Strengthened Glass or IG-3/16" Heat Strengthened Glass/ Laminate-3/16" Heat Strengthened Glass/0.100" Solutia Interlayer/3/16" Heat Strengthened Glass or IG-3/16" Tempered Glass/ Laminate-3/16" Heat Strengthened Glass/0.100" Solutia Interlayer/3/16" Heat Strengthened Glass Frame: W-6096mm(240") W-6096mm(240") 3048mm(120") Panel: W-1257mm(49.5") H-2998mm(118.03")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-05 TAS 201/202/203-94 ASTM E1886-02/E1996-02	SD-C44 6096 x 6096 x 3048 (240 x 240 x 120) Design Pressure: +44/-44 psf Wind Zone 4-Missile Level D Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3755-1/NCTL-210-3755-1A/W-1533
Expiration Date: May 31, 2027

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "MD" or similar, written over a horizontal line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

**4794 George Washington Memorial Highway
Hayes, VA 23072**

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023