

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI009044.03-R4  
**DATE:** 12/10/2012  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Eastern  
**CODE:** 1783-1  
**REVISION DATE:** 04/14/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS                                                                        | PRODUCT DESCRIPTION                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |
|-------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Eastern Architectural Systems</b><br><b>10030 Bavaria Road</b><br><b>Ft. Myers, FL 33913</b> | <b>Series "90° FD8100-LMI" Impact Rated</b><br><b>90 Degree Aluminum Sliding Glass Door</b><br><br>Configuration: XXXXXXXX<br>Four Track<br><br>Glazing: Laminate-3/16" Heat Strengthened Glass/0.100" Solutia<br>Interlayer/3/16" Heat Strengthened Glass or<br>IG-3/16" Heat Strengthened Glass/<br>Laminate-3/16" Heat Strengthened Glass/0.100" Solutia Interlayer/3/16"<br>Heat Strengthened Glass or<br>IG-3/16" Tempered Glass/<br>Laminate-3/16" Heat Strengthened Glass/0.100" Solutia Interlayer/3/16"<br>Heat Strengthened Glass<br><br>Frame: W-6096mm(240") W-6096mm(240")<br>2794mm(110")<br><br>Panel: W-1257mm(49.5") H-2699mm(106.25") |

| SPECIFICATION                                                                                        | PRODUCT RATING                                                                                                                                                       |
|------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b><br><b>TAS 201/202/203-94</b><br><b>ASTM E1886-02/E1996-02</b> | <b>SD-C60 6096 x 6096 x 2794 (240 x 240 x 110)</b><br><b>Design Pressure: +60/-60 psf</b><br><b>Wind Zone 4-Missile Level D</b><br><b>Large Missile Impact Rated</b> |

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-3755-1/NCTL-210-3755-1A/W-1533  
Expiration Date: May 31, 2027

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "S. D." or similar, written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023