

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006179.01-R2
DATE: 04/13/2011
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1
REVISION DATE: 06/18/2015

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 10030 Bavaria Road Ft. Myers, FL 33913	Series "FWI 6000" Aluminum Impact Rated Sliding Glass Door Glazing: Laminate-3/16" Heat Strengthened Glass/ 0.090" Saflex Keepsake Maximum/ 3/16" Heat Strengthened Glass Frame: W-5029mm(198") H-2438mm(96") Panel: W-1295mm(51") H-2413mm(95")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: +80/-80 psf Large Missile Impact Rated

Product Tested By: Fenestration Testing Laboratory, Inc.
Report No: Lab No. 3751/Report No. 3/File No. 02-311/W-1584
Expiration Date: June 30, 2020

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122