

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009416.04-R2  
DATE: 04/14/2011  
CERTIFICATION PROGRAM: Structural  
COMPANY: Eastern  
CODE: 1783-1  
REVISION DATE: 02/09/2016

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Eastern Architectural Systems</b> <b>16341 Domestic Avenue</b> <b>Fort Myers, FL 33912</b>	<b>Series "FD-8100" Aluminum</b> <b>Impact Sliding Glass Door</b>  Configuration: OXXX  Glazing: Laminate-3/16"Heat Strengthened Glass/0.100"Interlayer (Eastman PVB)/ 3/16"Heat Strengthened  Frame: W-6096mm(240") H-2794mm(110")  Panel: W-1527mm(60.12") H-2746mm(108.12")  DLO: W-1340mm(52.75") H-2546mm(100.25")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b> <b>ASTM E1886-02/05/E1996-02/05</b> <b>TAS 201/202/203-94</b>	<b>SD-R50 6096 x 2794 (240 x 110)</b> <b>Wind Zone 4-Missile Level D</b> <b>Design Pressure: +50/-50 psf</b> <b>Large Missile Impact Rated</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-3519-1/210-3519-1A  
Expiration Date: May 31, 2021

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "MD", is written over a horizontal line.

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122