

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009448.02
DATE: 07/14/2015
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 16341 Domestic Avenue Ft. Myers, FL 33912	Series "FWI 6000" Aluminum Impact Rated Sliding Glass Pocket Door Glazing: Laminate-1/8" Heat Strengthened Glass/ 0.090" PVB by Eastman/1/8" Heat Strengthened Glass Frame: W-3658mm(144") H-2438mm(96") Panel: W-1251mm(49.25") H-2400mm(94.5") Pocket: W-406mm(16") H-2438mm(96")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-05 ANSI/AAMA/NWDA 101/I.S.2-97 ASTM E1886-02/E1996-02	SD-R45 3658 x 2438 (144 x 96) SGD-R45 (144 x 96) Design Pressure: ±2155 Pa (45 psf) Wind Zone 3-Missile Level D

Product Tested By: Architectural Testing, Inc.
Report No: ATI-66544.03-401-44/66544.04-401-44
Expiration Date: October 31, 2020

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122