

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010632.02-R1
DATE: 12/10/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1
REVISION DATE: 07/13/2015

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|---|
| Eastern Architectural Systems 16341 Domestic Avenue Ft. Myers, FL 33912 | Series "135" FD8100-LMI" Aluminum Impact Rated Sliding Glass Pocket Door Configuration: XXXXXXXX Four Track Glazing: Laminate-3/16" Heat Strengthened Glass/0.100" Solutia Interlayer/3/16" Heat Strengthened Glass or IG-3/16" Heat Strengthened Glass/ Laminate-3/16" Heat Strengthened Glass/0.100" Solutia Interlayer/3/16" Heat Strengthened Glass Frame: W-4877mm(192") W-4877mm(192") 2794mm(110") Panel: W-1245mm(49") H-2699mm(106.25") |

| SPECIFICATION | PRODUCT RATING |
|--|--|
| AAMA/WDMA/CSA 101/I.S.2/A440-05 TAS 201/202/203-94 ASTM E1886-02/E1996-02 | SD-C50 4877 x 4877 x 2794 (192 x 192 x 110) Design Pressure: +50/-50 psf Wind Zone 4-Missile Level D Large Missile Impact Rated |

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3756-1/NCTL-210-3756-1A/W-1533
Expiration Date: October 31, 2020

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122