

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013349-R2
DATE: 08/22/2016
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1
REVISION DATE: 10/16/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 16341 Domestic Avenue Ft. Myers, FL 33912	Series "143 Vinyl Impact HR" Vinyl Horizontal Slider (New Construction & Replacement) Configuration: XO Glazing: IG-1/8" Annealed Glass/Laminate-1/8" Annealed Glass/0.090" Eastman Interlayer/1/8" Annealed Glass Frame: W-1880mm(74.02") H-1600mm(63") Panel: W-927mm(36.5") H-1543mm(60.75") DLO: W-864mm(34.02") H-1518mm(59.75")

SPECIFICATION	PRODUCT RATING
AAMA 506-11 AAMA/WDMA/CSA 101/I.S.2/A440-11 ASTM E1886-05/E1996-09	Design Pressure: 2400 Pa (50 psf) Class LC-PG50 1880 x 1600 (74 x 63)-HS Wind Zone 4-Missile Level D Water Penetration Resistance Test Pressure: 574 Pa(12.00 psf)

Product Tested By: Element Materials Technology
Report No: ESP014366P-2_3002 W-2
Expiration Date: **December 31, 2028**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "MD", written over a horizontal line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

email: nami@namiinc.com