

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013349.01
DATE: 07/29/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 16341 Domestic Avenue Ft. Myers, FL 33912	Series "143 Vinyl HR" Vinyl Horizontal Slider (New Construction & Replacement) Configuration: XO Glazing: Insulated Glass (Annealed) Frame: W-1854mm(73") H-1575mm(62") Panel: W-927mm(36.5") H-1543mm(60.75") DLO: W-843mm(33.19") H-1448mm(57")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class LC-PG50 1854 x 1575 (73 x 62)-HS Design Pressure: 2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 574 Pa(12.00 psf)

Product Tested By: Element Materials Technology
Report No: ESP014366P-3
Expiration Date: July 31, 2029

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com

NOPC-03/30/2023