

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI006149.01-R1  
**DATE:** 04/26/2011  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Eastern  
**CODE:** 1783-1  
**REVISION DATE:** 06/16/2014

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Eastern Architectural Systems</b> <b>10030 Bavaria Road</b> <b>Ft. Myers, FL 33913</b>	<b>Series "FWI 1000" Aluminum</b> <b>Impact Rated Horizontal Sliding Window</b>  Configuration: OX  Glazing: Laminate-3/16" Heat Strengthened Glass/ 0.090" Saflex/Keepsake Maximum/ 3/16" Heat Strengthened Glass  Frame: W-1829mm(72") H-1524mm(60") Panel: W-914mm(36") H-1448mm(57")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b> <b>AAMA 1302.5-76</b>	<b>Design Pressure: +80/-80 psf</b> <b>Large Missile Impact Rated</b> <b>FER-Passed</b>

Product Tested By: Fenestration Testing Laboratory, Inc.  
Report No: Lab No. 3701/Report No. 25/File No. 02-311  
Expiration Date: December 31, 2019

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122