

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010634.02-R4
DATE: 05/23/2011
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1
REVISION DATE: 02/09/2016

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 16341 Domestic Avenue Ft. Myers, FL 33912	Series "4241" Vinyl H.R. Equal Leg Impact Rated Horizontal Sliding Window Configuration: XO Glazing: IG-1/8" Annealed Glass/Laminate-1/8" Annealed Glass/0.090" Interlayer (Eastman PVB)/ 1/8" Annealed Glass Frame: W-1816mm(71.5") H-1511mm(59.5") Panel: W-889mm(35") H-1422mm(56")

SPECIFICATION	PRODUCT RATING
ASTM E1886-05/E1996-05	Design Pressure: +50/-50 psf Wind Zone 4-Missile Level D

Product Tested By: Certified Testing Laboratories
Report No: CTLA-2062W-9
Expiration Date: March 31, 2021

Administrator's Signature: _____ 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122