

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI008093-R7
DATE: 06/04/2007
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 11/19/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series "4780" Aluminum Sliding Glass Door w/o Sill Adapter Configuration: XX Glazing: Insulating Glass (Tempered) Frame: W-2438mm(96") H-2438mm(96") Panel: W-1156mm(45.5") H-2413mm(95")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/NWDA 101/I.S.2-97	Class R-PG25 2438 x 2438 (96 x 96)-SD SGD-R25 2438 x 2438 (96 x 96) Positive Design Pressure: 1200 Pa (25 psf) Negative Design Pressure: 2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 180 Pa (3.75 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-10734-2/W-1981
Expiration Date: May 31, 2030

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "MD" or similar, written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023