

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI008093.03-R4
DATE: 05/30/2008
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 11/19/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 615 Carson Street Bryan, TX 75247	Series "4780" Aluminum Sliding Glass Door w/Steel Reinforcement Configuration: OXXX Glazing: Insulating Glass (Tempered) Frame: W-4877mm(192") H-2438mm(96") Panel: W-1231mm(48.5") H-2413mm(95")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/NWWDA 101/I.S.2-97	Class R-PG35 4877 x 2438 (192 x 96)-SD SGD-R35 Design Pressure: ±1676 Pa (±35 psf) Water Penetration Resistance Test Pressure: 251 Pa (5.25 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-11212-1/NCTL-110-11276-1/W-1391/W-1981/W-2010
Expiration Date: **April 30, 2030**

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023