NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI010680-R8**
DATE:	**06/20/2011**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Sun-Tek**
CODE:	**225-1**
REVISION DATE:	**08/18/2025**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Sun-Tek Manufacturing, Inc. **10303 General Drive** **Orlando, FL 32824**	**Series "CMG II"** **Aluminum Glazed Skylight** Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-1664mm(65.5") H-2578mm(101.5") DLO: W-1524mm(60") H-2438mm(96")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 **AAMA/WDMA/CSA 101/I.S.2/A440-08** **AAMA/WDMA/CSA 101/I.S.2/A440-05**	**Class CW-PG60 1664 x 2578 (66 x 102)-RWG** **Class CW-PG60 1664 x 2578 (66 x 102)-SKG-RW** **SKG/RW-C60 1664 x 2578 (66 x 102)**

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3676-1/W-1969
Expiration Date: **September 30, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com