

Hallmark® Certificate of Conformance and License (CCL)





Pella Corporation
102 Main Street
Pella, IA 50219

Mfr ID: 411
For more Information visit www.amscert.com
Website:
TEL: 641-621-3820

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
411-H-1470.04	Pella 350 Series Sliding Window	101/I.S.2/A440-11	Class LC-PG40; Size Tested 2896 x 1829mm (114 x 72in) Type-HS; Can. Air Infil/Exfil. Level=A3	2896mm	1829mm	ESP017944P.3	1/5/2015	10/13/2024
411-H-1470.05	Pella 350 Series Sliding Window	101/I.S.2/A440-08	Class LC-PG40; Size Tested 2896 x 1829mm (114 x 72in) Type-HS; Can. Air Infil/Exfil. Level=A3	2896	1829	ESP017944P.3	1/5/2015	10/13/2024

WDMA HEREBY CERTIFIES that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected by WDMA, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  **John McFee, VP of Certification Programs, WDMA Hallmark**

By:  **Rhonda Schotz, Authorized Representative, AMS**

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 100 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com