

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011074-R4
DATE: 04/25/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Nan Ya Plastics
CODE: 661-1
REVISION DATE: 06/18/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Nan Ya Plastics Corp. USA/ Neuma Doors 4016 Shadrack St. Houston, TX 77013	"Out-Swing Entrance Door w/Sidelites" Fiberglass Glazed Side-Hinged Doors w/Glazed Fixed Panels Configuration: OXXO Glazing: Insulating Glass (Tempered/Annealed) Frame: W-3635mm(143.13") H-2096mm(82.5") Panel: W-876mm(34.5") H-2040mm(80.32") DLO: W-635mm(25") H-1601mm(63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG70 3635 X 2096 (144 x 83)-SHD Qualifies Configurations: O/X/OX/XO/OXO/XX/OXX/XXO/OXXO

Product Tested By: Fenestration Testing Laboratory, Inc.
Report No: FTL # 6716
Expiration Date: April 30, 2032

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "MD".

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023