

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011075-R4
DATE: 04/25/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Nan Ya Plastics
CODE: 661-1
REVISION DATE: 06/18/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Nan Ya Plastics Corp. USA/ Neuma Doors 4016 Shadrack St. Houston, TX 77013	"In-Swing Entrance Door w/Sidelites" Fiberglass Impact Glazed Side-Hinged Door w/Impact Glazed Fixed Panels Configuration: OXXO Glazing: IG- 1/8" Tempered Glass/Laminate- 1/8" Annealed Glass/0.090" DuPont Butacite PVB/1/8" Annealed Glass Frame: W-3639mm(143.25") H-2096mm(82.5") Panel: W-876mm(34.5") H-2010mm(79.13") DLO: W-635mm(25") H-1601mm(63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA 506-08 ASTM E1886-05/1996-05	Class R-PG50 3639 X 2096 (144 x 83)-SHD Design Pressure: +50/-50 psf Large Missile Impact Rated Wind Zone 4 - Missile Level D Qualifies Configurations: O/X/OX/XO/OXO/XX/OXX/XXO/OXXO

Product Tested By: Fenestration Testing Laboratory, Inc.
Report No: FTL # 6718
Expiration Date: April 30, 2032

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

**4794 George Washington Memorial Highway
Hayes, VA 23072**

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023