

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011058.01  
**DATE:** 01/16/2013  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Nan Ya  
**CODE:** 661-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Nan Ya Plastics Corporation USA</b> <b>8989 North Loop East, Suite 800</b> <b>Houston, TX 77029</b>	<b>Series "In-Swing Entrance Door with Sidelites" Fiberglass In-Swing Side Hinged Double Door w/Sidelites</b>  Configuration: OXXO  Glazing: Insulating Glass(Tempered & Annealed)  Frame: W-3703mm(145.75) H-2096mm(82.50") Panel: W-876mm(34.50") H-2008mm(79.07") Sidelite: W-876mm(34.50") H-2008mm(79.07") DLO: W-635mm(25.00") H-1601mm(63.00")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b>	<b>Class R-PG60 3639 x 2096 (144 x 83)-LW SHD</b> <b>Design Pressure = 2872 Pa (60 psf)</b> <b>Positive Design Pressure = 2872 Pa (60 psf)</b> <b>Negative Design Pressure = 2872 Pa (60 psf)</b> <b>Water Penetration Resistance Test Pressure = 287 Pa (6.00 psf)</b> <b>Qualifies Configurations: O/X/OX/XO/OXX/XXO/OXO/OXXO</b>

Product Tested By: Fenestration Testing Laboratory, Inc.  
Report No: FTL 6719/W-1549  
Expiration Date: **April 30, 2015**

A handwritten signature in black ink, appearing to be "Shelby", written over a horizontal line.

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124/ Fax: (804) 684-5122