

Hallmark® Certificate of Conformance and License (CCL)



AMS, INC.
Administrative Management
Systems, Inc.

Weather Shield Mfg. Inc.
1 Weathershield Plaza
PO Box 309
PO Box 309
Medford, WI 54451-0309

Mfr ID: 449
For more Information visit www.amscert.com
Website:
TEL: 715-748-2100

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
449-H-041.01	V2500 Single Hung Tilt (9107)	101/I.S.2/A440-08	Class R-PG50; Size Tested 902mm x 1816mm (36" x 72") Type-H; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A2	902mm	1816mm	ESP011021P-1305	1/2/2015	8/22/2022
449-H-041.02	V2500 Single Hung Tilt (9107) 2-wide	101/I.S.2/A440-08	Class R-PG50; Size Tested 1816mm x 1816mm (72" x 72") Type-H; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A2	1816mm	1816mm	ESP011021P-1305	1/2/2015	8/22/2022
449-H-041.03	V2500 Single Hung Tilt (9107) - Vertical Mullion	AAMA 450-10	Class R-PG50; Size Tested 914mm Trib area x 1816mm span (36trib area/71.5in span) Type-MA; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A2	914mm Trib area	1816mm span	ESP011021P-1305	1/2/2015	8/22/2022

WDMA HEREBY CERTIFIES that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected by WDMA, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  *John McFee, VP of Certification Programs, WDMA Hallmark*

By:  *Rhonda Schotz, Authorized Representative, AMS*

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 100 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com