

Hallmark® Certificate of Conformance and License (CCL)



Windsor Windows and Doors
900 South 19th Street
West Des Moines, IA 50265

Mfr ID: 453

For more Information visit www.amscert.com

Website: www.windsorwindows.com

TEL: 515-223-6660

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
453-H-043.06	Pinnacle Select Clad Operator Casement	101/I.S.2/A440-11	Class LC-PG65; Size Tested 2794mm x 1829mm * Type-C; DP +65/-65 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A3	2794mm	1829mm	ESP027324P	4/16/2018	2/5/2028
453-H-043.08	Pinnacle Select Clad Operator Casement	ASTM E1996-14a/ ASTM E-1886-13a	DP +65/-65 psf, Missile D, Wind Zone 4	2794mm	1829mm	ESP027324P.ASTM	4/10/2018	1/18/2028
453-H-043.09	Pinnacle Select Clad Operator Casement	TAS 201/202/203-94	DP +65/-65 psf, Large Missile, Wind Zone 4	2794mm	1829mm	ESP127324P.DADE	5/3/2018	12/22/2027
453-H-043.15	Pinnacle Select Crank Out Casement Impact	ASTM E1996-14a/ ASTM E-1886-13a	DP +65/-65 psf, Missile D, Wind Zone 4	2794 mm	2134mm	ESP029189P.ASTM	10/22/2018	9/18/2028
453-H-043.16	Pinnacle Select Crank Out Casement Impact	TAS 201/202/203-94	DP +65/-65 psf	2794 mm	2134 mm	ESP029189P.DADE	10/23/2018	9/27/2028
453-H-043.17	Pinnacle Select Crank Out Casement Impact	101/I.S.2/A440-11	Class CW-PG65; Size Tested 2794 mm x 2134 mm Type-C; DP +65/-65 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A3	2794 mm	2134 mm	ESP029189P.1	10/19/2018	8/28/2028
453-H-043.21	Pinnacle Select Push Out Casement	101/I.S.2/A440-11	Class CW-PG65; Size Tested 2794 mm x 2134 mm Type-C; DP +65/-65 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A3	2794 mm	2134 mm	ESP029277P.1	12/6/2018	11/7/2028
453-H-043.22	Pinnacle Select Push Out Casement	ASTM E1996-14a/ ASTM E-1886-13a	DP +65/-65 psf, Missile D, Wind Zone 4	2794 mm	2134 mm	ESP029277P.ASTM	12/11/2018	11/7/2028
453-H-043.23	Pinnacle Select Push Out Casement	TAS 201/202/203-94	DP +65/-65 psf	2794 mm	2134 mm	ESP029277P.Casement Impact	12/10/2018	9/11/2028

Hallmark® Certificate of Conformance and License (CCL)



AMS, INC.
Administrative Management
Systems, Inc.

Windsor Windows and Doors
900 South 19th Street
West Des Moines, IA 50265

Mfr ID: 453

For more Information visit www.amscert.com

Website: www.windsorwindows.com

TEL: 515-223-6660

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
-------------	--------------	----------	--------	------	------	---------------	----------	---------

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By: John McFee John McFee, VP of Certification Programs, WDMA Hallmark

By: Rhonda Schotz Rhonda Schotz, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com