

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016366.06
DATE: 10/24/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Silverline
CODE: 3108-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Silverline Building Products 5020 Weston Parkway Cary, NC 27513	Series "2000" Model "2001/2111" Vinyl Single Hung Window Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1143mm(45") H-1575mm(62") Sash: W-1100mm(43.31") H-775mm(30.50") DLO: W-1029mm(40.50") H-695mm(27.38")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class R-PG40 1143 x 1575* (45 x 62*)-H Design Pressure: ± 1920 Pa (± 40 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Intertek, PLC
Report No: D4558.01-109-47
Expiration Date: October 31, 2028

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S. D." or similar, written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023