

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016367.01
DATE: 10/24/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Silverline
CODE: 3108-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Silverline Building Products 5020 Weston Parkway Cary, NC 27513	Series "2200/2300" Model "2201/2301" Vinyl Single Hung Window (Fin) Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1219mm(48") H-2134mm(84") Sash: W-1170mm(46.06") H-1054mm(41.50") DLO: W-1105mm(43.50") H-994mm(39.13")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class R-PG20 1219 x 2134 (48 x 84)-H Design Pressure: ± 960 Pa (± 20 psf) Water Penetration Resistance Test Pressure: 150 Pa (3.13 psf)

Product Tested By: Intertek, PLC
Report No: G0995.01-109-47
Expiration Date: October 31, 2028

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023