

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016367.06
DATE: 10/28/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Silverline
CODE: 3108-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Silverline Building Products 5020 Weston Parkway Cary, NC 27513	Series "2200/2300/2600" Model "2201/2301/2601" Vinyl Single Hung Window Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1321mm(52") H-1854mm(73") Sash: W-1272mm(50.06") H-914mm(36") DLO: W-1210mm(47.63") H-838mm(33")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG25 1321 x 1854 (52 x 73)-H Design Pressure: ± 1200 Pa (± 25 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Architectural Testing, Inc.
Report No: D0714.01-109-47
Expiration Date: October 31, 2028

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "SMD", written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023