NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI016387**
DATE:	**11/05/2024**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Silverline**
CODE:	**3108-1**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Silverline Building Products **5020 Weston Parkway** **Cary, NC 27513**	**Series "V1/2200/2300"** **Model "2251/2351"** **Vinyl Picture Window** Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-965mm(38") H-1346mm(53") DLO: W-851mm(33.50") H-1235mm(48.63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 **AAMA/WDMA/CSA 101/I.S.2/A440-08**	**Class R-PG60 965 x 1346* (38 x 53*)-FW** **Design Pressure: ±2880 Pa (±60 psf)** **Water Penetration Resistance Test Pressure: 440 Pa (9.20 psf)**

Product Tested By: Intertek, PLC
Report No: G8443.01-201-47/G8442.01-201-47
Expiration Date: **November 30, 2028**

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com