

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO:	NI016388.03
DATE:	11/05/2024
CERTIFICATION PROGRAM:	Structural
COMPANY:	Silverline
CODE:	3108-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Silverline Building Products 5020 Weston Parkway Cary, NC 27513	Series "V1/2900/4900" Model "2952 IG" Vinyl Direct Set Twin Picture Window Configuration: OO Glazing: Insulating Glass (Annealed) Frame: W-2438mm(96") H-1880mm(74") DLO: W-1089mm(42.88") H-1753mm(69")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class R-PG35 2438 x 1880 (96 x 74)-FW Design Pressure: ± 1680 Pa (± 35 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf)

Product Tested By: Intertek, PLC
Report No: G9448.01-201-47
Expiration Date: **November 30, 2028**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023