NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI016388.07**
DATE:	**11/05/2024**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Silverline**
CODE:	**3108-1**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Silverline Building Products **5020 Weston Parkway** **Cary, NC 27513**	**Series "V1/2900/4900"** **Model "2952/4952"** **Vinyl Twin Fixed Window** Configuration: OO Glazing: Insulating Glass (Annealed) Frame: W-2416mm(95.13") H-1219mm(48") DLO: W-1095mm(43.13") H-1095mm(43.13")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	**Class R-PG50 2416 x 1219 (95 x 48)-FW** **Design Pressure: ±2400 Pa (±50 psf)** **Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)**

Product Tested By: Intertek, PLC
Report No: D4555.01-109-47
Expiration Date: **November 30, 2028**

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com