

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016389.08
DATE: 11/05/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Silverline
CODE: 3108-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Silverline Building Products 5020 Weston Parkway Cary, NC 27513	Series "V3/3000/3900" Model "3051/3951" Vinyl Fixed Window Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-2438mm(96") H-1372mm(54") DLO: W-2318mm(91.25") H-1248mm(49.13")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class R-PG50 2438 x 1372 (96 x 54)-FW Design Pressure: ± 2400 Pa (± 50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Intertek, PLC
Report No: G9000.01-109-47
Expiration Date: November 30, 2028

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023