

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016454.01-R1
DATE: 03/18/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Silverline
CODE: 3108-1
REVISION DATE: 03/11/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Silverline Building Products 5020 Weston Parkway Cary, NC 27513	Series "70" Vinyl Fixed Window (2130/2135 Flange - 2351/2361 Nail Fin) Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-965mm(38") H-1346mm(53") DLO: W-851mm(33.50") H-1226mm(48.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 TAS 202-94	Class R-PG60 965 x 1346 (38 x 53)-FW Design Pressure: ± 2880 Pa (± 60 psf) Water Penetration Resistance Test Pressure: 470 Pa (9.75 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-15663-1/NCTL-110-15663-2
Expiration Date: March 31, 2029

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com