NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI016427.01**
DATE:	**12/10/2024**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Silverline**
CODE:	**3108-1**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Silverline Building Products **5020 Weston Parkway** **Cary, NC 27513**	**Series "8700"** **Vinyl Horizontal Sliding Window** **(Finless)** Configuration: XX Glazing: Insulating Glass (Annealed) Frame: W-1854mm(73") H-1600mm(63") Sash: W-914mm(36") H-1508mm(59.38") DLO: W-835mm(32.88") H-1426mm(56.13")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	**Class LC-PG50 1854 x 1600 (73 x 63)-HS** **Design Pressure: ±2400 Pa (±50 psf)** **Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)**

Product Tested By: Intertek, PLC
Report No: F9656.01-109-47
Expiration Date: **December 31, 2028**

Administrator's Signature:_____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com