

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016427.06
DATE: 12/10/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Silverline
CODE: 3108-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Silverline Building Products 5020 Weston Parkway Cary, NC 27513	Series "8700/8700" Vinyl Horizontal Sliding Window (Finless) Configuration: XX Glazing: Insulating Glass (Annealed) Frame: W-1854mm(73") H-914mm(36") Sash: W-914mm(36") H-829mm(32.63") DLO: W-835mm(32.88") H-737mm(29")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class R-PG40 1854 x 914* (73 x 36*)-HS Design Pressure: ± 1920 Pa (± 40 psf) Water Penetration Resistance Test Pressure: 290 Pa (6.06 psf)

Product Tested By: Architectural Testing, Inc.
Report No: D7152.01-109-47/D2943.01-109-47
Expiration Date: December 31, 2028

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023